



Drinking Water Results Report

Order ID: 1B03225

Suburban Water Technology 1697A Swamp Pike Gilbertsville, PA 19525 Attn: Jeremy Crum	Project: The Laboratory Charter School 926 West Sedgley Avenue Philadelphia, PA 19140 PWSID:
---	---

Sample Number: 1B03225-01	Site: 3rd Floor Kit Cold	Sample ID: 9239
Collector: WW	Collect Date: 02/16/2021 11:30 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Copper	0.501	mg/L	EPA 200.8	1.3	Pass	0.010	02/19/21	RPV	02/19/21 16:18	RPV
Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	02/19/21	MKR	02/19/21 16:18	RPV

Sample Number: 1B03225-02	Site: 3rd Floor Fountain	Sample ID: 9239
Collector: WW	Collect Date: 02/16/2021 11:35 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Copper	0.161	mg/L	EPA 200.8	1.3	Pass	0.010	02/19/21	RPV	02/19/21 16:36	RPV
Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	02/19/21	MKR	02/19/21 16:36	RPV

Sample Number: 1B03225-03	Site: 2nd Floor Fountain	Sample ID: 9239
Collector: WW	Collect Date: 02/16/2021 11:40 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Copper	0.818	mg/L	EPA 200.8	1.3	Pass	0.010	02/19/21	RPV	02/19/21 16:40	RPV
Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	02/19/21	MKR	02/19/21 16:40	RPV

Sample Number: 1B03225-04	Site: 1st Floor Copy Room Cold	Sample ID: 9239
Collector: WW	Collect Date: 02/16/2021 11:45 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Copper	0.430	mg/L	EPA 200.8	1.3	Pass	0.010	02/19/21	MKR	02/19/21 16:45	RPV
Lead	0.008	mg/L	EPA 200.8	0.015	Pass	0.001	02/19/21	MKR	02/19/21 16:45	RPV

Sample Number: 1B03225-05	Site: 1st Floor Fountain	Sample ID: 9239
Collector: WW	Collect Date: 02/16/2021 11:48 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Report Generated On: 02/23/2021 1:22 pm 1B03225
STL_DW_Results Revision #1.7 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 1B03225-05	Site: 1st Floor Fountain	Sample ID: 9239
Collector: WW	Collect Date: 02/16/2021 11:48 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
Metals										
Copper	0.299	mg/L	EPA 200.8	1.3	Pass	0.010	02/19/21	MKR	02/19/21 16:49	RPV
Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	02/19/21	MKR	02/19/21 16:49	RPV

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

**** This report has been Amended (Rev1) and replaces all previous reports for this order ID ****

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

MCL: Maximum Contaminant Level based on 40CFR part 141 and 143. MCL and Pass/Fail are provided for reference only.

RL: Reporting Limit. The lowest concentration reported for this sample. Results below the RL are considered Non-Detected.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
Project Manager I


Report Generated On: 02/23/2021 1:22 pm 1B03225
STL_DW_Results Revision #1.7 Effective: 07/09/2014

1037F MacArthur Road, Reading, PA 19605 Phone: 800-433-6595 Fax: 610-375-4090 suburbantestinglabs.com



PADEP 06-00208

Suburban Water Tec
 1697 Swamp Pike
 Gilbertsville, PA 19525



1B03225
 Lisa F. Care



(610) 367-6464 Ph (610) 367-4950 Fax

Date Water Test Order 9239

Sold To:
 THE LABORATORY CHARTER SCHOOL
 926 WEST SEDGLEY AVENUE
 PHILADELPHIA, Pennsylvania 19140

Picked Up at:
 926 WEST SEDGLEY AVENUE
 PHILADELPHIA, Pennsylvania 19140

Customer Phone 1: 267-817-4720
 267-817-4720

Fax:

eMail: CEO @ labcharter.com
 wmathis @ labcharter.com

Paid:

By:

PAST DUE BALANCE:

	eMail Results to:
--	-------------------

Item	Test Required	Sample Site Description	Date	Time	Initials	Bottle Quantity	Column A	Column B
							Matrix	Sample Type
000014A	LEAD & COPPER WATER TEST	3rd floor Kit cold	2/16/21	11:30	WW	1	PW	G
000014B	LEAD & COPPER WATER TEST	3rd floor Fountain	2/16/21	11:35	WW	1	PW	G
000014C	LEAD & COPPER WATER TEST	2nd floor Fountain	2/16/21	11:40	WW	1	PW	G
000014D	LEAD & COPPER WATER TEST	1st floor copy room cold	2/16/21	11:45	WW	1	PW	G
000014E	LEAD & COPPER WATER TEST	1st floor Fountain	2/16/21	11:48	WW	1	PW	G
						Total Bottles	5	

(5) 500 mL P
 -11/10/03 PH 42 IN

Relinquished By: 2/16/21 1500

Received By: 2/16/21 1500

ON ICF? ... For Suburban Water Tech Use Only

Suburban Testing Labs

Lab Date/Time: 2/16/21 1830 **Lab Temp:** 1.5°C ICE

Number of containers/coolers match number on COC? Y N

Sample labels and COC are free of discrepancies? Y N

All containers in tact? Y N

Received in lab within acceptable temperature limits? Y N

40mL VOA vials free of headspace? Y N

Relinquished by:

Received in Lab by: